

ANNUAL REPORT

Drinking-Water System Number: 220002743
Drinking-Water System Name: Airport Drinking Water System
Drinking-Water System Owner: County of Brant
Drinking-Water System Category: Large Municipal - Residential
Period being reported: January 1, 2018 to December 31, 2018

Complete if your Category is Large Municipal Residential or Small Municipal Residential:

Does your Drinking-Water System serve more than 10,000 people? Yes No

Is your annual report available to the public at no charge on a web site on the Internet? Yes No

Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection:
County of Brant Administration Office (26 Park Ave., Burford, ON.)

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

None

Did you provide a copy of your annual report to all Drinking Water System owners that are connected to you and whom you provide all of its drinking water?

- Yes
- No
- Not applicable

Indicate how you notified system users that your annual report is available, and is free of charge:

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method: Notice in water bill.

Describe your Drinking-Water System

The Airport Drinking Water System consists of:

- a) One drilled well completed in the overburden equipped with a vertical turbine pump capable of pumping 26.6 l/s;
- b) A sodium hypochlorite dosing system to provide disinfection via chlorination;

- c) A 423 m³ single cell baffled water storage reservoir;
- d) A high lift pump station with two 9.46 l/s normal duty pumps and two 47.31 l/s fire duty pumps;
- e) A maximum rated daily capacity of 2,290 m³/day; and
- f) The distribution system that services approx. 272 residences and 25 commercial accounts.

Emergency standby power is provided to the entire station via a diesel motor powered generator.

All equipment is located at 9 Airport Road, which is near the Brantford Airport. The surrounding land use is light industrial.

List all water treatment chemicals used over this reporting period

12 % Sodium Hypochlorite Solution

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment

Brief description and a breakdown of monetary expenses incurred:

There were no significant expenses in 2018.

In 2019 new water production and treatment facilities will be constructed to replace the existing, a new well will be added to production, and an elevated tank will be constructed to replace the buried reservoir. Estimated construction cost is \$8.1M.

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O. Reg. 170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
none					

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period

	# of Samples	Range of E.Coli or Fecal Results (cfu/100ml)	Range of Total Coliform Results (cfu/100ml)	Range of BKG Results (cfu/100ml)	# of HPC Samples	Range of HPC Results (cfu/1ml)
Raw Well #1	52	0-0	0-0	0-1	52	<10-130
Treated	52	0-0	0-0	0-0	52	<10-20
Distribution	158	0-0	0-0	0-4	158	<0-NDOGHPC*

*NDOGHPC means non-determinate overgrowth of HPC. HPC was not present in next sampling event.

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report

	Number of Grab Samples	Range of Results
Turbidity – Raw Manual (Well #1)	12	0.03NTU – 0.14 NTU
Free Chlorine – Treated Online	8760	0.65-1.04
Free Chlorine – Daily Distribution Grab & Flushing + Bacti sampling	633	0.39-0.92
Fluoride (If the DWS provides fluoridation)	Not applicable	Not applicable

NOTE: Record the unit of measure if it is not milligrams per litre.
For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirements of an approval, order or other legal instrument

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
None required				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results (POE)

Parameter	Sample Date (mm/dd/yy)	Result Value	Unit of Measure	Exceedance
Antimony	01/02/18	<0.00050	mg/l	No
Arsenic	01/02/18	<0.0010	mg/l	No
Barium	01/02/18	0.13	mg/l	No
Boron	01/02/18	0.013	mg/l	No
Cadmium	01/02/18	<0.00010	mg/l	No
Chromium	01/02/18	<0.0050	mg/l	No
Mercury	01/02/18	<0.0001	mg/l	No
Selenium	01/02/18	<0.0020	mg/l	No
Uranium	01/02/18	0.00029	mg/l	No
Fluoride	01/02/18	0.11	mg/l	No
Sodium	01/02/18	13	mg/l	No
Nitrite (as N)	02/05/18	<0.010	mg/l	No
	05/10/18	<0.010	mg/l	No

Parameter	Sample Date (mm/dd/yy)	Result Value	Unit of Measure	Exceedance
	08/02/18	<0.010	mg/l	No
	11/01/18	<0.010	mg/l	No
Nitrate (as N)	02/05/18	0.99	mg/l	No
	05/10/18	1.45	mg/l	No
	08/02/18	1.88	mg/l	No
	11/01/18	1.22	mg/l	No
Nitrate + Nitrite (as N)	02/05/18	0.99	mg/l	No
	05/10/18	1.45	mg/l	No
	08/02/18	1.88	mg/l	No
	11/01/18	1.22	mg/l	No

Summary of lead testing under Schedule 15.1 during this reporting period

(Applicable to the following drinking-water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Date (mm/dd/yy)	Number of Samples	Range of Lead Results (min#) – (max#)	Number of Exceedances
Plumbing	Not required			
Distribution	Not required			

Summary of Organic parameters sampled during this reporting period or the most recent sample results (POE)

Parameter	Sample Date (mm/dd/yy)	Result Value	Unit of Measure	Exceedance
1,1-Dichloroethylene	01/02/18	<0.10	µg/l	No
1,2-Dichlorobenzene	01/02/18	<0.20	µg/l	No
1,2-Dichloroethane	01/02/18	<0.20	µg/l	No
1,4-Dichlorobenzene	01/02/18	<0.20	µg/l	No
2,3,4,6-Tetrachlorophenol	01/02/18	<0.50	µg/l	No
2,4,6-Trichlorophenol	01/02/18	<0.50	µg/l	No
2,4-Dichlorophenoxy acetic acid (2,4-D)	01/02/18	<1.0	µg/l	No
2-4 Dichlorophenol	01/02/18	<0.25	µg/l	No
Alachlor	01/02/18	<0.50	µg/l	No

Parameter	Sample Date (mm/dd/yy)	Result Value	Unit of Measure	Exceedance
Aroclor 1016	01/02/18	<0.05	µg/l	No
Aroclor 1221	01/02/18	<0.05	µg/l	No
Aroclor 1232	01/02/18	<0.05	µg/l	No
Aroclor 1242	01/02/18	<0.05	µg/l	No
Aroclor 1248	01/02/18	<0.05	µg/l	No
Aroclor 1254	01/02/18	<0.05	µg/l	No
Aroclor 1260	01/02/18	<0.05	µg/l	No
Atrazine	01/02/18	<0.50	µg/l	No
Atrazine + N-dealkylated metabolites (Atrazine+Desethyl-atrazine)	01/02/18	<1.0	µg/l	No
Benzene	01/02/18	<0.10	µg/l	No
Benzo(a)pyrene	01/02/18	<0.0090	µg/l	No
Bromoxynil	01/02/18	<0.50	µg/l	No
Carbaryl	01/02/18	<5.0	µg/l	No
Carbofuran	01/02/18	<5.0	µg/l	No
Carbon Tetrachloride	01/02/18	<0.10	µg/l	No
Chlorobenzene	01/02/18	<0.10	µg/l	No
Chlorpyrifos	01/02/18	<1.0	µg/l	No
Desethyl-atrazine	01/02/18	<0.50	µg/l	No
Diazinon	01/02/18	<1.0	µg/l	No
Dicamba	01/02/18	<1.0	µg/l	No
Diclofop-methyl	01/02/18	<0.90	µg/l	No
Dimethoate	01/02/18	<2.5	µg/l	No
Diquat	01/02/18	<7.0	µg/l	No
Diuron	01/02/18	<10	µg/l	No
Glyphosate	01/02/18	<10	µg/l	No
Guthion	01/02/18	<2.0	µg/l	No
Malathion	01/02/18	<5.0	µg/l	No

Parameter	Sample Date (mm/dd/yy)	Result Value	Unit of Measure	Exceedance
MCPA	01/02/18	<10	µg/l	No
Methylene Chloride	01/02/18	<0.50	µg/l	No
Metolachlor	01/02/18	<0.50	µg/l	No
Metribuzin	01/02/18	<5.0	µg/l	No
Paraquat	01/02/18	<1.0	µg/l	No
Pentachlorophenol	01/02/18	<0.50	µg/l	No
Phorate	01/02/18	<0.50	µg/l	No
Picloram	01/02/18	<5.0	µg/l	No
Total PCB	01/02/18	<0.05	µg/l	No
Prometryne	01/02/18	<0.25	µg/l	No
Simazine	01/02/18	<1.0	µg/l	No
Terbufos	01/02/18	<0.50	µg/l	No
Tetrachloroethylene	01/02/18	<0.10	µg/l	No
THM Total (distribution)				
110 Aviation Ave.	02/05/18	5.88	µg/l	No
37 Isabel Dr. (sample station)	05/10/18	5.55	µg/l	No
6 York Rd	08/02/18	4.17	µg/l	No
Greens Road (sample station)	11/01/18	5.97	µg/l	No
Total Haloacetic Acids (distribution)				
HYD 1-001 Airport Rd.	02/05/18	<5.0	µg/l	No
HYD 1-001 Airport Rd.	05/10/18	<5.0	µg/l	No
HYD 1-001 Airport Rd.	08/02/18	<5.0	µg/l	No
HYD 1-001 Airport Rd.	11/01/18	<5.0	µg/l	No
Toluene	01/02/18	<0.20	µg/l	No
Triallate	01/02/18	<1.0	µg/l	No
Trichloroethylene	01/02/18	<0.10	µg/l	No
Trifluralin	01/02/18	<1.0	µg/l	No
Vinyl Chloride	01/02/18	<0.20	µg/l	No

Non regulatory RAW WATER samples were taken from the Airport Well to gain operational information and were analyzed for the parameters listed in the table below:

Parameter	Sample Date (mm/dd/yy)	Result Well #1	Result Well #2	Unit of Measure
Dissolved Chloride	02/01/18	29	No pump	mg/l
	05/08/18	29	No pump	mg/l
	08/01/18	29	No pump	mg/l
	11/02/18	29	No pump	mg/l
Nitrate (as N)	02/01/18	0.96	No pump	mg/l
	05/08/18	1.43	No pump	mg/l
	08/01/18	1.85	No pump	mg/l
	11/02/18	1.19	No pump	mg/l
Sulphate	02/01/18	46	No pump	mg/L
	05/08/18	43	No pump	mg/l
	08/01/18	43	No pump	mg/l
	11/02/18	50	No pump	mg/l

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards

Parameter	Result Value	Unit of Measure	Date of Sample (mm/dd/yy)
None			